

STEEL CONDUIT [CLASS 4]

Rigid steel conduit conforms to the following specification relating to cable management systems: BS 4568 part 1: 1970 Clauses 4, 5.1, 5.4, 6.1, 7.1, 7.2, 8 and 9, BS EN 61386-21:2004 Clauses 7.1, 7.5, 8.1, 8.2, 9.1, 10.3, 10.4, and 14.2.2.3 (high protection).

The base structure is 20mm (or 25mm or 32mm) seam welded steel tube processed from hot rolled steel strip.

BS 4568 heavy protection is achieved by the hot dipped galvanising method to the thickness required under BS 4568 and EN 50086.



ACCREDITED TO THE FOLLOWING STANDARDS:



132

Uniklip

